



**Town of Salem NH
Police Department
Furnace Replacement**

BID (2020-019)

**Addendum No. 1
December 1, 2020**

Following specifications/questions have been posed to Christine Wholley Purchasing Agent, per November 30, 2020 walk through at Salem NH Police Department since the release of this BID, Answers are below.

1. Square footage of the Salem NH Police department is approx. 11,500
2. Install insulation valve
3. 80+ efficiently needed
4. There is no mechanical reason the Town would need a larger furnace, please provide a furnace of similar size/BTU to the existing furnace. This will change the existing specifications in the bid.
5. A low ambient kit is suggested to maintain a longer life of the furnace

PLEASE NOTE BID OPENING:

Via Zoom December 10, 2020 @ 11:00am, details on the Town website www.townofsalemnh.org under current bids and proposals.